

# CERTIFICATE

**Sto SE & Co. KGaA**


Ehrenbachstraße 1 · D-79780 Stühlingen  
have voluntarily subjected their product

## StoSil Struktur Medium

to inspection and testing according to the

**TÜV SÜD Test Standard TM 10**  
“Dispersion interior plaster” Issue 01-2022

The examination has furnished proof that the standard mentioned above is fulfilled in its entirety.



Sto SE & Co. KGaA are granted the right to use the  
TÜV Mark >> Low emission, Pollutant tested and Production monitored <<  
according to contract.

This certificate is valid until 25.04.2028

Certificate-Nr. TM-10 / 250807-9

Munich, 07.08.2025



Gabriele Glomsda  
Department Analytical Chemistry



Add value.  
Inspire trust.

TÜV SÜD Industrie Service GmbH · Ridlerstrasse 65 · 80339 Munich · Germany

Sto SE & Co. KGaA  
Ehrenbachstrasse 1

79780 Stühlingen  
Germany

Your reference/letter of	Our reference/name	Tel. extension/Email	Fax extension	Date	Page
	IS-USL-MUC/ Holger Struwe	+49 89 5791-2636 holger.struwe@tuvsud.com	+49 89 5791-2229	2025-08-04 KT_StoSil Struktur Medium 08- 2025_EN.docx	1 of 1

## Evaluation of the emission characteristics and toxic and environmentally relevant constituents of StoSil Struktur Medium

On behalf of Sto SE & Co. KGaA, TÜV SÜD Industrie Service GmbH tested a sample of the coating **StoSil Struktur Medium** regarding the criteria for the award of the TM-10 TÜV mark, "Low-emission, Pollutant tested and Production monitored". The results are described in detail in Test Report No. 25-S1428-29, dated 07.08.2025.

### The results can be summarised as follows:

- Solvent-free according to VdL-RL-01 (VOC content < 700 mg/kg)
- Plasticizer-free according to VdL-R-L01 (plasticizer content < 700 mg/kg)
- Preservative-free according to DE-UZ 102
- Formaldehyde-free according to VdL-RL-01 (free formaldehyde < 2 mg/kg)
- Formaldehyde emissions tested according to AgBB (28th day value: < 10 µg/m<sup>3</sup>)
- CMR emissions tested according to AgBB (28th day value: < 1 µg/m<sup>3</sup>)
- Low emissions tested according to AgBB (28th day value: TVOC < 300 µg/m<sup>3</sup>)
- No heavy metals (the proportion of substances with bioavailability lies within the limits set by Safety of Toys standard EN 71-3)

**StoSil Struktur Medium** meets the stringent criteria of TÜV SÜD's test standard TM-10 "dispersion interior plasters", Version 01-2022. Under normal processing and application conditions (see the current version of the technical data sheet), no adverse effects on the processor or user are expected.

Yours faithfully,

(Dipl.-Ing. (FH) Holger Struwe)  
Project leader building products

(Dr. Maria Wagenstaller)  
Technical expert building products

**Headquarters: Munich**  
Trade Register Munich HRB 96869  
VAT ID No. DE129484218  
Information pursuant to § 2 [1] DL-InfoV  
(Germany) at tuvsud.com/imprint

**Supervisory Board:**  
Walter Reithmaier (Chairman)  
**Board of Management:**  
Simon Kellerer (CEO)  
Thomas Kainz  
Ferdinand Neuwieser  
Paula Pias Peleteiro

**TÜV SÜD Industrie Service GmbH**  
Abteilung Chemische Analytik  
Ridlerstrasse 65  
80339 Munich  
Germany  
Phone: +49 89 5791-2206

tuvsud.com/de-is  
Hotline: +49 89 5190-4001

**TÜV®**